REINHOLD ENVIRONMENTAL Ltd.



2014 NOx-Combustion Round Table & Expo Presentations

February 10 & 11, 2014, in Charlotte, NC / Hosted by Duke Energy

All presentations posted on this website are copyrighted by Reinhold Environmental, Ltd (RE). Any unauthorized downloading, attempts to modify or to incorporate into other presentations, link to other websites, or obtain copies for any other uses than the training of attendess to RE's Conferences is expressively prohibited, unless approved in writing by RE or the original presenter. RE does not assume any liability for the accuracy or contents of any materials contained in this library which were presented and/or created by persons who were not employees of RE.











Balancing LNB vs SCR Catalyst Layers Bill Medeiros, P.E. Riley Power Scott Rutherford, Cormetech

Overview of Tradeoffs in a New Era

2014 Reinhold NOx-Combustion Round Table Charlotte, NC





Overview

- Historical Background How We Got Here
- What Has Changed
- Options & Trade-Offs Going Forward
- Conclusions/Recommendations





Historical Background

- Vast Majority of Fuels Bituminous
 - Some Powder River Basin
 - Other Fuels
 - Pet Coke
 - Fuel outlook seemed more certain except for units that were not scrubbed yet
 - Major Issues
 - Arsenic
 - High Arsenic Concentrations with Low Calcium Concentrations
 - European Experience
 - SO₃ Emissions
 - LPA





Historical Background

- Operational Considerations
 - Ozone season and year round
 - All new catalyst (HC, plate, corrugated)
 - Base loaded
 - European and Japanese experience base for maintenance expectations
- Reagent
 - Anhydrous
 - Big Shift to Urea
 - Issues with Surrounding Community
 - Aqueous
 - Smaller Units





New (and Renewed) Issues


- Fuels
 - Western Bituminous
 - Powder River Basin
 - Greater Deactivation Levels prevalent on Staged Combustion Units
- Mercury Emissions
 - SCR Hg Oxidation as a Co-Benefit
- Lower SO₃ Levels
 - Effect of SO₃ on Powder Activated Carbon Usage
 - Opacity Issues With SO₂ Control Equipment
 - Wet Scrubbers
 - Higher need to balance with catalyst life & Co-benefit drivers
- Longer initial catalyst life expectations
 - Up to 32k hours vs. 16-24k hours





New (and Renewed) Issues

- Operational Considerations
- Base Loaded Units Being Run at Lower Load
 - Natural Gas Pricing & Renewables










New (and Renewed) Issues

- Short-Term to intermediate-term SCR layup
 - Boiler shutdown
 - SCR bypass (tonnage vs. rate)
- Reagent
 - Renewed Interest in Aqueous and Anhydrous Ammonia









Options for Low Load and Start UP NOx Control

- Oversize SCR/Catalyst for Increased NOx Removal
- Flue Temperature Control
 - Flue Gas Bypass, Water Side Bypass,
 etc. → Impact on Heat Rate
- Reduced Temperature Variation
- Reduced NOx Removal at Lower Load
 - ABS Formation Temperature = Function (H₂O, SO₃, NH₃)
 - Lower Ammonia Concentrations
 Reduces Minimum Operating
 Temperature











Options for Low Load and Start UP NOx Control

- Transient SCR Operation Temporary Operating Below ABS Formation Temperature
- Additional Combustion Control For When SCR is Not in Operation
- Extended Range For Gas Firing
- Reduction in Number of Start Ups





Brief NOx Reduction Technology Comparison

Technology	LNB/OFA	SNCR	SCR
Reduction, %	30-60	20-50	90+
Advantages	• Cost • simplicity	• Cost	Reduction and emissionsPot. Hg co-benefits
Disadvantages	LOIcorrosionlimited reduction	 Limited reduction Risk of NH₃ slip poor reagent util. 	CostSO3 conversionpressure loss

Note: Technologies can be used in combination





Unit Design Basis

- 500 MW
- 9,500 Btu/Kwh
- Flue Gas Temperature at MCR 670 °F
- Ammonia Slip 2 ppm
- Arrangement High Dust SCR, ESP/Baghouse, WFGD
 Uncontrolled NOx (lbs/Mmbtu)


Fuel	Wall Fired	Tangential Fired
PRB	0.42	0.35
Western Bituminous	0.63	0.48





Combustion Modifications

- Reduced Catalyst & potential reactor cost
 - Incremental Cost of Increased
 NOx Reduction on SCR
- Proven Technology
- Reduced Reagent Cost
- Reduced Catalyst Cost
- NOx removal at Low Load/Start Up
- Combustion Control Impact on Catalyst Life



VS III[®] (Venturi Series)







Typical Low NOx Burner and Over fired Air Results

Coal Type	Wall Fired		Tangential Fired	
	Lbs./Mmbtu	%	Lbs./Mmbtu	%
PRB	0.22	47.6%	0.17	51.4%
Western Bituminous	0.32	49.2%	0.23	52.1%





Catalyst Design Basis

- Fuel PRB or Western Bituminous
- Initial Catalyst Life 24,000 hours
- Initial Catalyst SO₂ Conversion Rate
 - 1% PRB
 - ½% Western Bituminous
- Catalyst Pitch = 8 mm (optional 7 mm)
- Inlet NOx & Removal Efficiency → variable based on LNB/OFA Configuration with Outlet NOx = 0.05 lb/mmbtu
- Distributions
 - NH3:NOx 5% RMS
 - Temperature +/- 20 °F
 - Velocity 15% RMS





Economic Evaluation Basis


- Electric Cost \$0.05/Kw-hr
- Plant Life 15 years
- Plant Load Factor 90%
- Discount Value 8%
- Ammonia Cost \$500/Ton
- Catalyst Cost \$5,500/m³
- Burner with Over Fired Air Cost \$12,000/MW
- Impact to PAC, halogens or other additive cost (not included)





Hg Oxidation Considerations

- Performance goals
 - 40% to 80+% Hg removal (not SCR Oxidation)
 - Considering APH, PM device, FGD influences translates to an SCR oxidation requirement of 20-80%













Hg Oxidation Considerations


Influences on performance











Others: H₂O, O₂, CO, HC's, NOx, NH3 (All values at SCR outlet)

(Note: Specific example cases shown above to illustrate tendencies.)







SCR Design With and Without LNB and OFA

- Firing Powder River Basin
- SO₂ Conversion Rate = 1%

Coal Type	Wall Fired		Tangential Fired	
	Without LNB-OFA	With LNB-OFA	Without LNB-OFA	With LNB- OFA
Required SCR NOx Reduction	88.1%	77.3%	85.7%	70.6%
Ammonia Flow, lbs/hr	690	320	560	227
Catalyst Volume, %	100%	129%	92%	108%
Flue Gas Pressure Drop, iwg	1.3	1.6	1.2	1.4

Complexity of Hg oxidation performance threshold must be evaluated on a case specific basis \rightarrow lower NH₃ assists however potential for higher deactivation may offsets.







Savings With and Without LNB and OFA

Wall Fired Firing PRB Fuel

Case	SCR Only	LNB & OFA	Difference
Power NPV	\$1,450,000	\$1,780,000	\$330,000
Ammonia NPV	\$12,000,000	\$5,600,000	(\$6,400,000)
Cost of LNB & OFA	N/A	\$6,000,000	\$6,000,000
Catalyst			\$3,200,000
Total			\$3,130,000

Additional cost assessment criteria for Hg oxidation may include one or all of the following; alternate catalyst, halogen addition, PAC.







Savings With and Without LNB and OFA

Tangential Fired Firing PRB Fuel

Case	SCR Only	LNB & OFA	Difference
Power NPV	\$1,300,000	\$1,560,000	\$260,000
Ammonia NPV	\$9,450,000	\$3,800,000	(\$5,650,000)
Cost of LNB & OFA	N/A	\$6,000,000	\$6,000,000
Catalyst			\$2,500,000
Totals			\$3,110,000

Additional cost assessment criteria for Hg oxidation may include one or all of the following; alternate catalyst, halogen addition, PAC.





SCR Design With and Without LNB and OFA

- Firing Western Bituminous
- SO₂ Conversion Rate = ½ %
- 10 X 15 Catalyst Arrangement, 3 initial Layers

Coal Type	Wall Fired		Tangential Fired	
	Without LNB-OFA	With LNB-OFA	Without LNB-OFA	With LNB- OFA
Required SCR NOx Reduction	92.1%	84.4%	89.6%	78.3%
Ammonia Flow, lbs/hr	1080	504	800	338
Relative Catalyst Volume, %	100%	98%	79%	78%
Flue Gas Pressure Drop, iwg	1.8	1.7	1.5	1.4

Complexity of Hg oxidation performance threshold must be evaluated on a case specific basis \rightarrow lower NH₃ assists however potential for higher deactivation may offsets.







Savings With and Without LNB and OFA

Wall Fired Firing Western Bituminous Fuel

Case	SCR Only	LNB & OFA	Difference
Power NPV	\$1,560,000	\$1,470,000	(\$90,000)
Ammonia NPV	\$18,200,000	\$8,500,000	(\$9,700,000)
Cost of LNB & OFA	N/A	\$6,000,000	\$6,000,000
Catalyst			\$800,000
Totals			(\$2,990,000)

Additional cost assessment criteria for Hg oxidation may include one or all of the following; alternate catalyst, halogen addition, PAC.





Savings With and Without LNB and OFA

Tangential Fired Firing Western Bituminous Fuel

Case	SCR Only	LNB & OFA	Difference
Power NPV	\$1,200,000	\$1,200,000	(\$100,000)
Ammonia NPV	\$13,500,000	\$5,700,000	(\$7,800,000)
Cost of LNB & OFA	N/A	\$6,000,000	\$6,000,000
Catalyst			\$650,000
Totals			(\$1,250,000)

Additional cost assessment criteria for Hg oxidation may include one or all of the following; alternate catalyst, halogen addition, PAC.





Conclusions/Recommendations

- Each unit will be case specific
- For Western Bituminous fuels, the installation of LNB/OFA will assist in the overall compliance cost
- However for PRB fuels, the installation of LNB/OFA may not assist in compliance cost if higher catalyst deactivation rates are not mitigated
- Optimization of staging level should be explored:
 - Reduce catalyst deactivation and related volume
 - Balance against increased ammonia/reagent cost
 - Consider impact on Hg oxidation potential
 - Consider impacts of additives (Halogen, poison mitigation, PAC)
 through cost/benefit analysis





BabcockPower